

# Armstrong (China) Investment Co., Ltd

## TEST REPORT

**SCOPE OF WORK**

Homogeneous Vinyl Floor

**REPORT NUMBER**

200330003SHF-002

**TEST DATE(S)**

2020-03-30- 2020-04-08

**ISSUE DATE**

2020-04-09

**PAGES**


5

**DOCUMENT CONTROL NUMBER**

LFT-APAC-SHF-OP-10k(May 1, 2019)

© 2020 INTERTEK

Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch



## Test Report

### Statement

- 1.This report is invalid without company's special seal for testing on assigned page.
- 2.This report is invalid without authorized person's signature.
- 3.This report is invalid where any unauthorized modification indicated.
- 4.Don't copy this report in partial (except full copy) without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.
- 5.Any holder of this document is advised that this report is for the exclusive use of Intertek's Customer and is provided pursuant to the agreement between Intertek and its Customer. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. This report was made with due care within the limitation of a defined scope of work and on the basis of information, materials and instructions received from the Customer or its nominated third parties. Intertek is under no obligation to refer to or report upon any facts or circumstances which are outside the specific instructions received and accepts no responsibility to any parties whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works. The tests results are not intended to be a recommendation for any particular course of action. Customer is responsible for acting as it sees fit on the basis of such results.
- 6.Intertek's written consent is required to use Intertek's name or logo on the object, product or service being tested. The observations and test results in this report relate only to the sample under test. This report alone does not indicate that the item, product or service has passed any Intertek certification program.

# Test Report

Issue Date: 2020-04-09 Intertek Report No. 200330003SHF-002  
 Applicant: Armstrong (China) Investment Co., Ltd  
 Address: 10F, Building B, Greenland Center, No.600, Mid Long Hua Road. Shanghai, China  
 Attn: Qiuci Li  
 Test Type : Performance test, samples provided by the applicant.

**Product Information**

<b>Product Name</b>	Homogeneous Vinyl Floor		<b>Brand</b>	/
<b>Sample Description</b>	Good condition		<b>Sample Amount</b>	9 pcs
			<b>Received Date</b>	2020-03-27,2020-03-30
<b>Sample ID</b>	<b>Model</b>	<b>Specification</b>		
S200330003SHF.001	/	/		

**Test Methods And Standards**

<b>Test Standard</b>	ISO 26987:2008
<b>Specification Standard</b>	/
<b>Test Conclusion</b>	The samples were tested according to the above standards, and the results are shown in the following page.

**Note:**

1.This report relates specifically to the sample(s) that were drawn and provided by the applicant or their nominated third party. The reported result(s) provide no warranty or verification on the sample(s) representing any specific goods and/or shipment and only relate to the sample(s) as received and tested.

**Report Authorized**

	
_____	_____
Name: Flora Fan	Name: Jackie Zhou
Title: Reviewer	Title: Project Engineer



## Test Report

Issue Date: 2020-04-09

Intertek Report No. 200330003SHF-002

### Test Items, Method and Results:

Test Item: Resistance to staining

Test Method: ISO 26987:2008

Conditioning: At a temperature of (23±2)°C and relative humidity of (50±5) % for a minimum of 24h

### Test Result:

Staining materials	Duration of contact	Types of cleaning	Results	Index
Iodine Solution(0.5%)	30 min.	Flowing water	Not affected	0

### Note:

1. The staining materials and duration of contact were specified by applicant.

### Interpretation and presentation of results as per ISO 26987:2008

Index	Effect of test after cleaning/abrasion
0	Not affected
1	Slight
2	Moderate
3	Severe

## Test Report

Issue Date: 2020-04-09

Intertek Report No. 200330003SHF-002

### Appendix A: Sample Received Photo



Front View(Test surface)



Back View

### Revision:

NO.	Date	Changes	Author	Reviewer
200330003SHF-002	2020-04-09	First issue	Jackie Zhou	Flora Fan